

MBALE Bunkoko WW**Report date:** 16th November**Table:** Water quality for Mbale during the week of 12th November 2015

Parameter	Unit	Monitoring points								National Standard For potable water quality (Water in Supply)
		Nabuy onga Raw water	Nabijo Raw water	Treated Water	Water in Supply					
					Mooni	Busam aga	Namat ala	Buge ma	Doko	
CODE		N050	N051	N052	N053	N054	N055	N056	N057	
pH	...	7.1	7.2	7.0	7.0	7.1	7.1	7.0	7.1	6.5 – 8.5
Turbidity	NTU	93	67	1.7	1.9	2.1	1.6	4.6	1.9	≤5.00
Colour	PTU	243	187	5	8	9	5	8	7	≤15
iron	mg/l	0.40	0.35	0.06	0.01	0.03	0.05	0.05	0.03	0.20
Res Aluminium	mg/l	N/A	N/A	0.02	0.00	0.01	0.04	0.03	0.02	0.30
Free chlorine	mg/l	N/A	N/A	0.6	0.25	0.2	0.25	0.21	0.17	0.20 – 0.50
Faecal - Coliforms	CFU/ 100 ml	840	720	0	0	0	0	0	0	0

NA: Not applicable