

MBALE Bunkoko WW**Report date:** 30th November**Table:** Water quality for Mbale during the week of 26th November 2015

Parameter	Unit	Monitoring points								National Standard For potable water quality
		Nabuyonga Raw water	Nabijo Raw water	Treated Water	Water in Supply					
					Mpolo goma	Jami	Kamankoli	Namatala	Bugema	
CODE		N067	N068	N069	N070	N071	N072	N073	N074	
pH	NA	7.33	7.22	7.19	7.2	7.1	7.1	7.12	7.17	6.5 – 8.5
Turbidity	NTU	67	56	0.02	0.22	0.26	1.23	1.25	2.57	≤5.00
Colour	PTU	1616	5824	10	2	0	5	5	5	≤15
iron	mg/l	0.50	0.45	0.06	0.08	0.04	0.03	0.09	0.05	0.20
Res Aluminium	mg/l	N/A	N/A	0.09	0.12	0.07	0.09	0.05	0.07	0.30
Free chlorine	mg/l	N/A	N/A	1.05	0.35	0.22	0.25	0.3	0.27	0.20 – 0.50
Faecal - Coliforms	CFU/ 100 ml	1800	1600	0	0	0	0	0	0	0

NA: Not applicable

MBALE-MANAFWA WW**Report date:** 30th November**Table:** Water quality for Manafwa during the week of 26th November 2015

Water Quality for Mandawa during the week of 20 November 2016								
Parameter	Unit	Raw water	Treated Water	Monitoring points				National Standard For potable water quality
				Water in Supply				
Code		N060	N061	Bugema mile 5 N062	Nauyo N063	Busiu N064	Kachong a N065	
pH	NA	6.8	7.24	7.35	7.36	7.42	7.47	6.5 – 8.5
Turbidity	NTU	67	0.7	1.0	0.8	1.8	1.2	≤5.00
Colour	PTU	435	4	8	4	3	8	≤15
Iron	mg/l	0.40	0.02	0.01	0.03	0.08	0.04	0.30
Residual Al	mg/l	N/A	0.00	0.00	0.00	0.00	0.00	0.20
Free chlorine	mg/l	N/A	1.93	0.51	0.52	0.49	0.5	0.20 – 0.50
Faecal - Coliforms	CFU/ 100 ml	5700	0	0	0	0	0	0

NA: Not applicable

