

**MBALE-MANAFWA WW****Report date:** 16<sup>th</sup> November**Table:** Water quality for Manafwa during the week of 12th November 2015

Parameter	Monitoring points							National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Treated Water	Water in Supply				
				Busano	Makhai	Lulwanda p/s	Nabumali Rd	
Code		N054	N055	N056	N057	N058	N059	
pH	...	6.7	6.9	7.0	7.2	7.1	7.3	6.5 – 8.5
Turbidity	NTU	94.4	1.3	1.2	1.0	1.1	1.0	≤5.00
Colour	PTU	700	6	4	5	8	3	≤15
Iron	mg/l	0.79	0.02	0.05	0.03	0.01	0.03	0.30
Residual Al	mg/l	N/A	0.00	0.00	0.00	0.00	0.00	0.20
Free chlorine	mg/l	N/A	1.00	0.24	0.27	0.22	0.19	0.20 – 0.50
Faecal - Coliforms	CFU/ 100 ml	3500	0	0	0	0	0	0

NA: Not applicable