

MBALE Bunkoko WW**Report date:** 25th November**Table:** Water quality for Mbale during the week of 19th November 2015

Table: Water quality for mobile during the week of 19 - November 2019										
Parameter	Unit	Monitoring points								National Standard For potable water quality (Water in Supply)
		Nabuy onga Raw water	Nabijo Raw water	Treated Water	Water in Supply					
					Mooni	Busamaga	Namat ala	Bugema	Doko	
CODE		N058	N059	N060	N061	N062	N063	N064	065	
pH	...	7.2	7.2	6.6	7.1	7.1	7.2	6.5	7.1	6.5 – 8.5
Turbidity	NTU	97.00	76.00	0.72	0.32	0.06	1.23	1.51	1.57	≤5.00
Colour	PTU	1224	1022	5	2	0	5	5	5	≤15
iron	mg/l	0.60	0.54	0.03	0.05	0.02	0.06	0.02	0.03	0.20
Residual Al	mg/l	N/A	N/A	0.06	0.10	0.05	0.07	0.06	0.04	0.30
Free chlorine	mg/l	N/A	N/A	1.55	0.55	0.52	0.5	0.49	0.27	0.20 – 0.50
Faecal - Coliforms	CFU/ 100 ml	1400	1200	0	0	0	0	0	0	0

N/A: Not applicable

MBALE-MANAFWA WW**Report date:** 25th November**Table:** Water quality for Manafwa during the week of 19th November 2015

Parameter	Monitoring points							National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Treated Water	Water in Supply				
				Mile 6	Musoto	Busobs	Busiu	
Code		N054	N055	N056	N057	N058	N059	
pH	...	6.7	6.9	7.0	7.2	7.1	7.3	6.5 – 8.5
Turbidity	NTU	94.4	1.30	1.20	1.00	1.10	1.00	≤5.00
Colour	PTU	700	6	4	5	8	3	≤15
Iron	mg/l	0.60	0.05	0.02	0.05	0.00	0.06	0.30
Residual Al	mg/l	N/A	0.00	0.00	0.00	0.00	0.00	0.20
Free chlorine	mg/l	N/A	1.61	0.39	0.42	0.41	0.4	0.20 – 0.50
Faecal - Coliforms	CFU/ 100 ml	6500	0	0	0	0	0	0

N/A: Not applicable