

MBARARA AREA**Report date:** 13th January-2016**Table:** Water quality for Selected zones in Mbarara during the week of 7th January-2016.

Table: Water quality for Selected Zones in Mbarara during the week of 7 - 13 January 2016.								
Paramete r	Monitoring points							National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final Water		Water in Supply			
				Boma Reservoi r	Central Town	Kaberebere	Bwizibwera	
CODE		N113	N114	N115	N116	N117	N118	
pH	...	7.0	7.3	7.2	7.1	6.8	7.0	5.5 – 8.5
Turbidity	NTU	140.00	1.00	1.00	1.00	2.00	1.00	≤5.00
Colour	PtCo.	1216	10	14	14	15	15	≤15
Iron	Mg/L	4.500	0.100	N/R	N/R	N/R	N/R	≤0.300
Residue Aluminium	Mg/L	N/A	0.14	N/R	N/R	N/R	N/R	≤0.20
Free chlorine	Mg/L	N/A	0.97	0.43	0.25	0.21	0.20	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	19000	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required