

**MBARARA AREA****Report date:** 5<sup>th</sup> July -2015**Table:** Water quality for selected points in Mbarara during the week of 1<sup>st</sup> July 2015

Parameter	Monitoring points								National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water	Water in Supply					
				Boma Reservoirs	Ruti	Rwebik ona	Bwizib wera	Mbarara Central Town	
pH	...	6.5	7.2	7.0	7.1	6.8	6.8	6.9	6.92
Turbidity	NTU	133	0.00	0.00	1.00	0.00	0.00	1.00	≤5.00
Colour	PTU	937	9	8	9	10	8	9	≤15
Free chlorine	mg/l	NA	0.97	0.30	0.26	0.21	0.30	0.25	0.20 – 0.50
Faecal - Coliforms	CFU/ 100 ml	107	0	0	0	0	0	0	0