

## MBARARA AREA

Report date: 4<sup>th</sup> June 2015

**Table** : Average water quality for Mbarara during the period of 1<sup>st</sup> June - 7<sup>th</sup> June 2015

Parameter	Monitoring points									National Standard For potable water quality (Water in Supply)
	Unit	Raw water (River Rwizi)	Final water	Reservoirs	Water in Supply					
				Boma Reservoirs	Rwebikona	Kamukuzi	Ruti	Biharwe	Mbarara Central Town	
pH	....	6.8	7.0	6.8	6.7	7.0	7.0	6.9	6.8	5.5 – 8.5
Turbidity	NTU	112	2	1	1	1	0	0	1	≤5
Colour	PtCo.	1090	10	10	10	11	8	7	11	≤15
Free chlorine	mg/L	N/A	1.25	0.30	0.20	0.30	0.27	0.20	0.25	0.20 – 0.50
Faecal -Coliform	CFU/ 100 mL	40	0	0	0	0	0	0	0	0

