

MBARARA AREA**Report date:** 2nd November 2015**Table:** Water quality for Selected zones in Mbarara during the week of 26th October 2015

Parameter				Monitoring points				National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply			
				Boma Reservoir	Ruti	Rwebik ona	Bwizibwer a	
Codes		N058	N05	N060	N061	N062	N063	
pH	6.6	6.9	6.4	6.6	6.8	6.8	5.5 – 8.5
Turbidity	NTU	141.00	1.00	1.00	2.00	1.00	1.00	≤5.00
Colour	PtCo.	1521	10	11	11	11	11	≤15
Iron	Mg/l	1.59	0.07	N/R	N/R	N/R	N/R	≤0.30
Residue Aluminium	Mg/l	N/A	0.17	N/R	N/R	N/R	N/R	≤0.20
Free chlorine	mg/L	NA	0.70	0.64	0.25	0.27	0.28	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	1500	0	0	0	0	0	0

NR: Not Required, NA: Not Applicable