

**MBARARA AREA****Report date:** 22<sup>nd</sup> June 2015**Table:** Average water quality for different zones in Mbarara during the week of 15<sup>th</sup> June 2015

Parameter	Monitoring points							National Standard For potable water quality (Water in Supply)	
	Unit	Raw water R. Rwizi	Final water	Water in Supply					Mbarara Town
				Biharwe Zone	Bwizibwera	Nyamitanga	Kamukuzi		
pH	...	6.71	7.12	7.10	6.60	6.73	7.08	6.81	6.5 – 8.5
Turbidity	NTU	133	0	1	0	0	0	0	≤5.00
Colour	PTU	896	10	13	7	8	11	10	≤15
Free chlorine	mg/l	N/A	0.97	0.2	0.2	0.37	0.35	0.25	0.20 – 0.50
Faecal - Coliforms	CFU/ 100 ml	5000	0	0	0	0	0	0	0