

**MBARARA AREA****Report date:** 27<sup>th</sup> July -2015**Table:** Water quality for selected points in Mbarara during the week of 20<sup>th</sup> July 2015

Parameter	Monitoring points								National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water	Water in Supply					
				Boma Reserv oirs	Biharwe zone	Kambere bere	Rwembik ona	Mbarara Central Town	
pH	...	7.3	6.8	6.8	6.7	6.7	6.6	6.7	6.5 – 8.5
Turbidity	NTU	89	0.00	1.00	0.00	0.00	1.00	2.00	≤5.00
Colour	PTU	489	7	10	9	9	9	10	≤15
Free chlorine	mg/l	N/A	1.34	0.4	0.24	0.24	0.25	0.25	0.20 – 0.50
Faecal - Coliforms	CFU/ 100 ml	4600	0	0	0	0	0	0	0