

MBARARA AREA**Report date:** 29th June -2015**Table:** Water quality for different zones in Mbarara during the week of 22nd June 2015

Parameter	Monitoring points								National Standard For potable water quality (Water in Supply)
	Unit	Raw water R. Rwizi	Final water	Water in Supply					
				Biharwe Zone	Bwizibwera	Nyamitanga	Kamukuzi	Mbarara Town	
pH	...	6.4	7.2	7.0	7.1	7.1	7.0	6.8	6.92
Turbidity	NTU	121	1	1	0	1	1	1	≤5.00
Colour	PTU	994	9	12	10	10	10	9	≤15
Free chlorine	mg/l	N/A	0.85	0.30	0.20	0.22	0.24	0.20	0.20 – 0.50
Faecal - Coliforms	CFU/ 100 ml	4803	0	0	0	0	0	0	0