

MBARARA AREA

Report date: 13th July -2015

Table: Water quality for Selected zones in Mbarara during the week of 6th July 2015

Parameter	Monitoring points								National Standard For potable water quality (Water in Supply)
	Unit	Raw water R. Rwizi	Final water	Water in Supply					
				Mbarar a Central Town	Kabereber e	Rwebikona	Bwizibw era	Biharw e	
pH	...	6.7	7.0	6.9	7.1	6.9	6.5	6.6	6.92
Turbidity	NTU	84	0	0	1	0	0	0	≤5.00
Colour	PTU	666	6	5	8	5	5	4	≤15
Free chlorine	mg/l	NA	0.86	0.20	0.20	0.20	0.25	0.20	0.20 – 0.50
Faecal - Coliforms	CFU/ 100 ml	44	0	0	0	0	0	0	0