



**NATIONAL WATER & SEWERAGE CORPORATION
WATER QUALITY MANAGEMENT DEPARTMENT**

MBULAMUTI AREA

Report date: 2nd March 2016

Table: Water quality for Mbulamuti during the week of 25th February 2016

Parameter	Monitoring points							National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Treated Water	Water in Supply				
				Health centre1V	Kadaga premises	Corner Psp	Bugondha P/S	
Code		N107	N108	N109	N110	N111	N112	
pH	...	7.7	7.5	7.5	7.5	7.7	7.6	6.5 – 8.5
Turbidity	NTU	2.51	0.51	0.49	0.53	0.50	0.48	≤5.00
Colour	PTU	29	0	0	0	0	0	≤15
Iron	mg/l	0.09	0.03	0.02	0.01	0.09	0.02	0.30
Residual Al	mg/l	N/A	0.00	0.00	0.00	0.00	0.00	0.20
Free chlorine	mg/l	N/A	0.59	0.38	0.23	0.35	0.20	0.20 – 0.50
Faecal - Coliforms	CFU/ 100 ml							0
		40	0	0	0	0	0	