



**NATIONAL WATER & SEWERAGE CORPORATION
WATER QUALITY MANAGEMENT DEPARTMENT**

MBULAMUTI

Report date: 10th June 2016

Table: Water quality for **Mbulamuti** during the week of 2nd June 2016

Parameter	Monitoring points							National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Treated Water	Water in Supply				
				Health centre1V	Kadaga premises	Corner Psp	Bugondha P/S	
Code		N313	N314	N315	N316	N317	N318	
pH	...	7.5	7.4	7.5	7.4	7.5	7.5	6.5 – 8.5
Turbidity	NTU	3.7	0.92	0.85	1.0	0.7	0.9	≤5.00
Colour	PTU	40	7	9	6	4	8	≤15
Iron	mg/l	0.08	0.06	0.05	0.08	0.00	0.06	0.30
Residual Al	mg/l	N/A	0.00	0.00	0.00	0.00	0.00	0.20
Free chlorine	mg/l	N/A	0.60	0.24	0.30	0.33	0.36	0.20 – 0.50
Faecal - Coliforms	CFU/ 100 ml	18	0	0	0	0	0	0

NA: Not applicable