

MBULAMUTI AREA**Report date:** 16th November**Table:** water quality for selected points in Mbulamuti Area during the week of 12th November 2015

Parameter	Monitoring point							National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Treated Water	Water in Supply				
				Health centre1 V	Ferry	Corner Psp	OPP.plant Remarks	
pH	...	7.7	7.6	7.7	7.5	7.6	7.7	6.5 – 8.5
Turbidity	NTU	3.9	0.81	1.61	1.99	1.46	0.89	≤5.00
Colour	Mg/l	22	0	0	2	2	0	500
Free chlorine	mg/l	N/A	0.62	0.32	0.31	0.29	0.68	0.20 – 0.50
Faecal - Coliforms	CFU/ 100 ml	25	0	0	0	0	0	0

NA: Not applicable