

MBULAMUTI AREA**Report date:** 25th November**Table:** water quality for selected points in Mbulamuti Area during the week of 19th November 2015

Parameter	Monitoring point							National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Treated Water	Water in Supply				
				Health centre1 V	Ferry	Corner Psp	OPP.plan t	
Code		N060	N061	N062	N063	N064	N065	
pH	...	7.6	7.8	7.6	7.5	7.5	7.6	6.5 – 8.5
Turbidity	NTU	2.42	1.22	1.41	1.49	1.42	1.59	≤5.00
Colour	Mg/l	20	0	0	0	2	0	500
Free chlorine	mg/l	N/A	0.67	0.36	0.21	0.39	0.58	0.20 – 0.50
Faecal - Coliforms	CFU/ 100 ml	13	0	0	0	0	0	0

N/A: Not applicable