



# NATIONAL WATER & SEWERAGE CORPORATION

## WATER QUALITY MANAGEMENT DEPARTMENT

**MBULAMUTI**

**Report date:** 25<sup>th</sup> January 2016

**Table:** Water quality for Selected zones in Mbale during the week starting 18<sup>th</sup> January-2016.

Parameter	Monitoring points						National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Treated Water	Water in Supply			
				Health centre1V	Kadaga premises	Corner Psp	
Code		N083	N084	N085	N086	N087	
pH	...	7.54	7.68	7.66	7.61	7.84	6.5 – 8.5
Turbidity	NTU	1.24	0.82	0.87	0.51	0.54	≤5.00
Colour	PTU	25	0	0	0	0	≤15
Iron	Mg/L	0.04	0.02	0.01	0.04	0.00	0.30
Residual Al	Mg/L	N/A	N/R	N/R	N/R	N/R	0.20
Free chlorine	Mg/L	N/A	0.65	0.32	0.29	0.36	0.20 – 0.50
Faecal - Coliforms	CFU/ 100 ml	34	0	0	0	0	0

NA: Not applicable, N/R: Not Required