

MITYANA AREA**Report date:** 6th January -2016**Table:** Water quality for Selected zones in Mityana during the week starting 28th December 2015

Parameter				Monitoring points					National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply				
				Buswab ulo	Kibaat i	Naama PSP	Naluga zi	Businzi go	
CODE		N098	N099	N100	N101	N102	N103	N104	
pH	5.9	6.5	6.7	6.7	6.8	6.6	6.8	5.5 – 8.5
Turbidity	NTU	13.85	0.93	1.04	1.34	1.24	0.70	2.09	≤5.00
Colour	PtCo.	570	0	0	0	0	0	0	≤15
Iron	Mg/l	12.75	0.11	N/A	N/A	N/A	N/A	N/A	≤0.30
Residue Aluminium	Mg/l	NR	0.10	N/A	N/A	N/A	N/A	N/A	≤0.20
Free chlorine	Mg/L	NR	0.7	0.30	0.23	0.20	0.21	0.20	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	78	0	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required