



**NATIONAL WATER & SEWERAGE CORPORATION
WATER QUALITY MANAGEMENT DEPARTMENT**

MITYANA AREA

Report date: 30th June-2016

Table: Water quality for Selected zones in Mityana during the week of 24th June 2016

Parameter				Monitoring points				National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply			
				Wabigalo	Butega	Buswabu lango	Kileku	
CODE		N3129	N3130	N3134	N3135	N3136	N3137	
pH	5.8	6.6	6.6	6.7	6.8	6.9	5.5 – 8.5
Turbidity	NTU	28.70	0.00	0.00	0.00	0.00	0.00	≤5.00
Colour	PtCo.	674	0	0	0	0	5	≤15
Iron	Mg/l	5.06	0.22	N/R	N/R	N/R	N/R	≤0.300
Residue Aluminium	Mg/l	N/A	0.035	N/R	N/R	N/R	N/R	≤0.20
Free chlorine	mg/L	NA	0.83	0.20	0.21	0.24	0.25	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	80	0	0	0	0	0	0