



**NATIONAL WATER & SEWERAGE CORPORATION  
WATER QUALITY MANAGEMENT DEPARTMENT**

**MITYANA AREA**

**Report date:** 10<sup>th</sup> June -2016

**Table:** Water quality for Selected points in **Mityana** during the week starting 2nd June 2016

Parameter				Monitoring points				National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply			
				Fremmer Jr sch	Kitinkolola	Butega	Mityana	
CODE		N1091	N1092	N1093	N1094	N1095	N1096	
pH	....	5.8	6.6	7.2	6.7	6.8	6.9	5.5 – 8.5
Turbidity	NTU	19.3	1.48	1.77	2.60	2.35	1.37	≤5.00
Colour	PtCo.	484	3	0	0	0	0	≤15
Iron	Mg/l	4.300	0.195	N/R	N/R	N/R	N/R	≤0.300
Residue Aluminium	Mg/l	N/R	0.066	N/R	N/R	N/R	N/R	≤0.20
Free chlorine	mg/L	N/R	1.00	0.20	0.21	0.20	0.23	0.20 – 0.50
Faecal-Coliform	CFU/ 100 mL	12	0	0	0	0	0	0