



**NATIONAL WATER & SEWERAGE CORPORATION  
WATER QUALITY MANAGEMENT DEPARTMENT**

**MITYANA AREA**

**Report date:** 6<sup>th</sup> April 2016

**Table:** Water quality for Selected zones in **Mityana** during the week of 30<sup>th</sup> March. 2016

Parameter				Monitoring points				National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply			
				Kigogwa	Busulwa bulango	Busuubuzi	Wabigal o	
Codes		N1080	N1081	N1085	N1086	N1088	N1089	
pH	....	6.0	6.6	7.2	7.3	7.3	7.3	5.5 – 8.5
Turbidity	NTU	58.20	0.66	1.03	0.83	0.69	0.48	≤5.00
Colour	PtCo.	742	6	10	8	7	5	≤15
Iron	Mg/l	1.44	0.278	N/A	N/A	N/A	N/A	≤0.300
Residue Aluminium	Mg/l	N/R	0.028	N/R	N/R	N/R	N/R	≤0.20
Free chlorine	Mg/L	N/A	1.00	0.40	0.20	0.20	0.23	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	4	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required