



**NATIONAL WATER & SEWERAGE CORPORATION  
WATER QUALITY MANAGEMENT DEPARTMENT**

**MITYANA AREA**

**Report date:** 24<sup>th</sup> February 2016

**Table:** Water quality for Selected zones in **Mityana** during the week of 18<sup>th</sup> February. **2016**

Parameter				Monitoring points				National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water	Water in Supply				
				Buswabulang o	Kibati	Mityana Taxi park	Nalugazi	
Codes		N116	N117	N118	N119	N120	N121	
pH	....	5.8	6.6	6.9	6.9	6.7	6.9	5.5 – 8.5
Turbidity	NTU	63.60	0.86	0.77	0.69	0.32	0.70	≤5.00
Colour	PtCo.	719	2.1	0	5	0	0	≤15
Iron	Mg/l	14.25	0.06	N/A	N/A	N/A	N/A	≤0.300
Residue Aluminium	Mg/l	NA	0.14	N/A	N/A	N/A	N/A	≤0.20
Free chlorine	Mg/L	N/A	0.96	0.20	0.10	0.20	0.20	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	13	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required