



**NATIONAL WATER & SEWERAGE CORPORATION
WATER QUALITY MANAGEMENT DEPARTMENT**

MITYANA AREA

Report date: 2nd March 2016

Table: Water quality for Selected zones in **Mityana** during the week of 25th February. 2016

Parameter				Monitoring points			National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water	Water in Supply			
				Nambale	kiganwa	Frenner Jr. Sch	
Codes		N461	N462	N463	N464	N465	
pH	5.8	6.8	7.18	6.88	6.75	5.5 – 8.5
Turbidity	NTU	48.5	0.97	1.17	0.3	0.75	≤5.00
Colour	PtCo.	608	5	15	5	10	≤15
Iron	Mg/l	14	0.09	N/A	N/A	N/A	≤0.300
Residue Aluminium	Mg/l	N/R	0.12	N/R	N/R	N/R	≤0.20
Free chlorine	Mg/L	NR	0.75	0.4	0.2	0.2	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	44	0	0	0	0	0

NA: Not applicable, N/R: Not Required