

MITYANA AREA**Report date:** 6th July 2015**Table:** Water quality for selected points in Mityana during the week of 1st July 2015

Parameter	Monitoring points							National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water	Water in Supply				
				Buswabal ongo	Busubuzi	kyitinkoko la	Busizing o	
pH	...	6.0	6.6	6.7	6.8	6.9	6.8	5.5 – 8.5
Turbidity	NTU	50	1.14	0.00	0.00	0.00	0.00	≤5.00
Colour	PtCo.	873	14	0	0	0	0	≤15
Free chlorine	mg/L	NA	0.73	0.20	0.10	0.20	0.10`	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	26	0	0	0	0	0	0