

MITYANA AREA

Report date: 4th June 2015

Table: Average water quality of selected Areas within **Mityana** during the period of 1st June - 7th June 2015

Parameter	Monitoring points								National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water	Water in Supply					
				Wabigalo PSP	Kyiganw a	Kyitinko -kola	Naama	Businzigo	
pH	...	6.1	6.7	6.5	7	6.5	6.5	6.5	5.5 – 8.5
Turbidity	NTU	62	2	0	0	0	0	0	≤5
Colour	PtCo.	1046	5	0	5	15	15	5	≤15
Free chlorine	mg/L	N/A	0.7	0.3	0.1	0.2	0.2	0.2	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	20	0	0	0	0	0	0	0