

MITYANA AREA**Report date:** 30th November-2015**Table:** Water quality for Selected zones in Mityana during the week starting 26th November 2015

Parameter				Monitoring points				National Standard For potable water quality
	Unit	Raw water	Final water		Water in Supply			
				Nambale	Wabigalo	Naama	Buswabu longo	
CODE		N067	N068	N069	N070	N071	N072	
pH	NA	5.53	6.3	6.8	7.05	6.8	6.96	5.5 – 8.5
Turbidity	NTU	30.96	1.74	1.74	2.07	1.16	1.38	≤5.00
Colour	PtCo.	808	10	5	0	5	10	≤15
Iron	Mg/l	9.94	0.05	N/A	N/A	N/A	N/A	≤0.30
Residue Aluminium	Mg/l	N/A	0.18	N/A	N/A	N/A	N/A	≤0.20
Free chlorine	Mg/L	NR	0.6	0.2	0.2	0.1	0.2	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	102	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required