

MITYANA AREA**Report date:** 2nd November-2015**Table:** Water quality for Selected zones in Mityana during the week starting 26th October 2015

Parameter				Monitoring points				National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply			
				Busuubizi	kyigan wa	Kitinkolola	Waabigalo	
CODE		N050	N051	N052	N053	N054	N055	
pH	5.3	6.4	6.5	6.6	6.6	6.6	5.5 – 8.5
Turbidity	NTU	12.40	1.53	1.55	1.44	1.1	1.19	≤5.00
Colour	PtCo.	552	12	15	10	10	10	≤15
Iron	Mg/l	10.40	0.06	N/R	N/R	N/R	N/R	≤0.30
Residue Aluminium	Mg/l	N/A	0.18	N/R	N/R	N/R	N/R	≤0.20
Free chlorine	Mg/L	NA	0.75	0.20	0.20	0.20	0.20	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	68	0	0	0	0	0	0

NA: Not applicable, N/R: Not Reported