

MITYANA AREA**Report date:** 8th December -2015**Table:** Water quality for Selected zones in Mityana during the week starting 3rd December 2015

Parameter				Monitoring points					National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply				
				Kiyigisu	Butega	Nambaa le	Kyigogwa PSP	Mityana prisons	
CODE		N070	N071	N072	N073	N074	N075	N076	
pH	5.6	6.5	6.7	6.7	6.7	6.7	6.7	5.5 – 8.5
Turbidity	NTU	26.4	0.86	1.34	1.36	0.62	2.54	2.53	≤5.00
Colour	PtCo.	762	14	5	10	5	5	15	≤15
Iron	Mg/l	12.70	0.06	N/A	N/A	N/A	N/A	N/A	≤0.30
Residue Aluminium	Mg/l	N/A	0.18	N/A	N/A	N/A	N/A	N/A	≤0.20
Free chlorine	Mg/L	NR	0.77	0.2	0.2	0.2	0.2	0.2	0.20 – 0.50
Faecal - Coliform	CFU/100 mL	65	0	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required