

MITYANA AREA**Report date:** 16th November-2015**Table:** Water quality for Selected zones in Mityana during the week starting 12th November 2015

Parameter				Monitoring points				National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply			
				Busuubizi	kyigan wa	Kitinkolola	Waabigalo	
CODE		N061	N062	N063	N064	N065	N066	
pH	6.5	6.8	6.7	7.0	6.8	6.7	5.5 – 8.5
Turbidity	NTU	24.40	1.33	1.35	1.24	1.18	1.89	≤5.00
Colour	PtCo.	945	9	8	7	10	11	≤15
Iron	Mg/l	11.20	0.06	N/R	N/R	N/R	N/R	≤0.30
Residue Aluminium	Mg/l	N/A	0.11	N/R	N/R	N/R	N/R	≤0.20
Free chlorine	Mg/L	NA	0.65	0.30	0.20	0.30	0.40	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	73	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required