

MITYANA AREA

Report date: 7th October-2015

Table: Water quality for Selected zones in Mityana during the week starting 12th October 2015

Parameter				Monitoring points					National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply				
				Busubuzi	Nambale	Mityana S.S	Kigogw a	Mityana prisons	
CODE		N037	N038	N039	N040	N041	N042	N043	
pH	5.4	6.5	6.8	6.6.7	6.6	6.7	6.6.7	5.5 – 8.5
Turbidity	NTU	14.80	0.85	0.91	0.55	0.47	0.64	1.57	≤5.00
Colour	PtCo.	450	5	0	5	0	0	10	≤15
Iron	Mg/l	11.900	0.080	NR	NR	NR	NR	NR	≤0.300
Residue Aluminium	Mg/l	N/A	0.15	NR	NR	NR	NR	NR	≤0.20
Free chlorine	mg/L	NA	0.72	0.20	0.20	0.20	0.20	0.20	0.20 – 0.50
Faecal - Coliform	CFU/100 mL	40	0	0	0	0	0	0	0

NR: Not required