

MITYANA AREA**Report date:** 22th June 2015**Table:** Water quality for selected points in Mityana during the week of 15th June 2015

Parameter	Monitoring points								National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water	Water in Supply					
				Buswabulong o	Intra College	Kibat i	Kitenkekela	Busizingo	
pH	...	5.60	4.30	7.11	6.90	6.64	6.49	6.64	5.5 – 8.5
Turbidity	NTU	16.1	0.87	1.70	2.51	1.63	1.55	1.42	≤5
Colour	PtCo.	750	14	10	6	10	15	10	≤15
Free chlorine	mg/L	N/A	0.6	0.2	0.2	0.3	0.2	0.2	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	24	0	0	0	0	0	0	0