

MITYANA AREA

Report date: 25th July 2015

Table: Water quality for selected points in Mityana during the week of 20th July 2015

Parameter	Monitoring points								National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water	Water in Supply					
				Mityan a S.S	Busubu zi	Naama	Wabiga lo PSP	Busizin go	
pH	...	5.3	6.3	6.3	6.5	6.4	6.5	6.3	5.5 – 8.5
Turbidity	NTU	32.00	1.24	0.89	0.64	0.53	0.73	0.80	≤5.00
Colour	PtCo.	410	17	5	5	5	5	5	≤15
Free chlorine	mg/L	N/A	0.70	0.10	0.10	0.20	0.20	0.20	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	42	0	0	0	0	0	0	0