

MITYANA AREA**Report date:** 29th September -2015**Table:** Water quality for Selected zones in Mityana during the week of 25th September 2015

Parameter	Unit	Raw water	Final water	Monitoring points					National Standard For potable water quality (Water in Supply)
				Reservoir A	Mityana s.s	Nambale	Busuubi bzi	Wabigalo	
Codes		N022	N023	N024	N025	N026	N027	N028	
pH	5.4	6.6	6.6	6.4	6.4	6.4	6.5	5.5 – 8.5
Turbidity	NTU	25.7	0.52	0.70	0.44	0.60	0.49	0.65	≤5.00
Colour	PtCo.	770	5	5	10	5	10	5	≤15
Iron	Mg/l	N/D	N/D	N/R	N/R	N/R	N/R	N/R	≤0.30
Residue Aluminium	Mg/l	N/A	0.15	N/R	N/R	N/R	N/R	N/R	≤0.20
Free chlorine	mg/L	N/A	0.96	0.25	0.27	0.26	0.20	0.21	0.20 – 0.50
Faecal Coliform -	CFU/100 mL	44	0	0	0	0	0	0	0

N/R-Not Required