

## MITYANA AREA

**Report date:** 7<sup>th</sup> October-2015

**Table:** Water quality for Selected zones in Mityana during the week of 2<sup>nd</sup> October 2015

Parameter				Monitoring points					National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply				
				Reserv oir A	Mityana s.s	Butega	Busuubibzi	Wabigalo	
CODE		N022	N023	N024	N025	N026	N027	N028	
pH	....	5.6	6.5	6.6	6.5	6.5	6.5	6.5	5.5 – 8.5
Turbidity	NTU	43.21	0.58	0.87	0.80	0.50	0.81	0.61	≤5.00
Colour	PtCo.	770	2	0	0	0	0	0	≤15
Iron	Mg/l	18.80 0	0.050	NR	NR	NR	NR	NR	≤0.300
Residue Aluminium	Mg/l	N/A	0.15	NR	NR	NR	NR	NR	≤0.20
Free chlorine	mg/L	NA	0.65	0.40	0.20	0.24	0.30	0.24	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	40	0	0	0	0	0	0	0