



NATIONAL WATER & SEWERAGE CORPORATION

WATER QUALITY MANAGEMENT DEPARTMENT

MITYANA AREA

Report date: 21st January-2016

Table: Water quality for Selected zones in Mityana during the week of 11th January-2016.

Parameter	Monitoring points						National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water	Water in Supply			
				kyigogwa	Kanamba	Nambale	
Codes		N098	N099	N100	N101	N102	
pH	5.9	6.5	7.9	7.2	7.4	5.5 – 8.5
Turbidity	NTU	14.9	1.76	1.83	1.60	1.09	≤5.00
Colour	PtCo.	463	5	0	5	0	≤15
Iron	Mg/L	11.750	0.14	N/A	N/A	N/A	≤0.300
Residue Aluminium	Mg/L	N/R	0.10	N/R	N/R	N/R	≤0.20
Free chlorine	Mg/L	NR	0.60	0.30	0.20	0.20	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	100	0	0	0	0	0

NA: Not applicable, N/R: Not Required