

MITYANA AREA**Report date:** 24th December -2015**Table:** Water quality for Selected zones in Mityana during the week starting 17th December 2015

Parameter				Monitoring points					National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply				
				Nakiwog o	Busam baga	Garuga	Kakind u	Kawuku	
CODE		N084	N085	N086	N087	N088	N089	N090	
pH	5.8	6.6	6.9	6.8	6.8	6.6	6.6	5.5 – 8.5
Turbidity	NTU	22.2	2.31	1.33	1.18	1.00	0.87	1.12	≤5.00
Colour	PtCo.	720	8	0	5	5	0	5	≤15
Iron	Mg/L	12.20	0.10	N/A	N/A	N/A	N/A	N/A	≤0.30
Residue Aluminium	Mg/L	N/A	0.10	N/A	N/A	N/A	N/A	N/A	≤0.20
Free chlorine	Mg/L	NR	0.70	0.20	0.20	0.20	0.20	0.20	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	60	0	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required