

MITYANA AREA**Report date:** 30th December -2015**Table:** Water quality for Selected zones in Mityana during the week of 24th December 2015

Parameter				Monitoring points					National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply				
				Kyigog wa	Namba le	Butega	Kyigis u	Mityan a Prisons	
CODE		N091	N092	N093	N094	N095	N096	N097	
pH	5.9	6.6	6.6	6.7	6.5	6.7	6.8	5.5 – 8.5
Turbidity	NTU	24.20	0.68	0.46	0.51	0.87	1.24	0.45	≤5.00
Colour	PtCo.	620	3	0	0	0	5	0	≤15
Iron	Mg/l	10.25	0.07	N/A	N/A	N/A	N/A	N/A	≤0.30
Residue Aluminium	Mg/l	N/A	0.10	N/A	N/A	N/A	N/A	N/A	≤0.20
Free chlorine	Mg/L	NR	0.60	0.20	0.23	0.20	0.21	0.20	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	78	0	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required