

**MUBENDE AREA****Report date:** 13<sup>th</sup> January-2016**Table:** Water quality for Selected zones in Mubende during the week of 7<sup>th</sup> January-2016.

Parameter	Monitoring points							National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply			
				PSP	C. Valve	Dead End	Boma	
CODES		56	61	66	69	72	64	
pH	....	7.6	6.6	6.7	6.7	6.8	6.6	5.5 – 8.5
Turbidity	NTU	12.00	0.00	0.00	0.00	0.00	0.00	≤5.00
Colour	PtCo.	443	0	0	0	0	0	≤15
Iron	Mg/L	0.530	0.000	N/R	N/R	N/R	N/R	≤0.300
Residue Aluminium	Mg/L	N/A	0.00	N/R	N/R	N/R	N/R	≤0.20
Free chlorine	Mg/L	N/A	0.86	0.22	0.36	0.15	0.28	0.20 – 0.50
Faecal – Coliform	CFU/ 100 mL	64	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required