



**NATIONAL WATER & SEWERAGE CORPORATION
WATER QUALITY MANAGEMENT DEPARTMENT**

MUBENDE AREA

Report date: 10th June-2016

Table: Water quality for Selected zones in Mubende during the week starting 2nd June 2016

Parameter				Monitoring points				National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water	Water in Supply				
				Lubanga road	Rwabagabo	Boma	kaweri	
CODE		N1078	N1083	N1089	N1090	N1086	M1087	
pH	8.2	7.7	6.5	6.6	6.5	6.6	5.5 – 8.5
Turbidity	NTU	19.00	0.00	0.00	0.00	0.00	0.00	≤5.00
Colour	PtCo.	340	0	0	0	0	0	≤15
Iron	Mg/l	0.81	0.00	N/R	N/R	N/R	N/R	≤0.300
Residue Aluminium	Mg/l	N/A	0.00	N/R	N/R	N/R	N/R	≤0.20
Free chlorine	mg/L	NA	1.09	0.20	0.20	0.25	0.36	0.20 – 0.50
Faecal - Coliform	CFU/100 mL	90	0	0	0	0	0	0