



**NATIONAL WATER & SEWERAGE CORPORATION  
WATER QUALITY MANAGEMENT DEPARTMENT**

**MUBENDE AREA**

**Report date:** 14<sup>th</sup> July 2016

**Table:** Water quality for Selected zones in Mubende during the week starting 11th July 2016

Parameter				Monitoring points				National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply			
				PSP Girungi	Asaba	Kibyayi	Kasenyi	
CODE		N1283	N1288	N1294	N1296	N1291	N1290	
pH	....	8.8	6.9	6.5	6.6	6.8	6.4	5.5 – 8.5
Turbidity	NTU	22.00	0.00	0.00	0.00	0.00	0.00	≤5.00
Colour	PtCo.	367	0	0	0	0	0	≤15
Iron	Mg/l	0.83	0.07	N/R	N/R	N/R	N/R	≤0.300
Residue Aluminium	Mg/l	N/A	0.02	N/R	N/R	N/R	N/R	≤0.20
Free chlorine	mg/L	NA	1.09	0.24	0.25	0.21	0.37	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	50	0	0	0	0	0	0