



**NATIONAL WATER & SEWERAGE CORPORATION**

**WATER QUALITY MANAGEMENT DEPARTMENT**

**MUBENDE AREA**

**Report date:** 23<sup>rd</sup> June-2016

**Table:** Water quality for Selected zones in Mubende during the week of 16th June 2016

Parameter				Monitoring points				National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply			
				PSP Kirungi	Kabasa njo	Kibyayi	Boma	
CODE		N1189	N1194	N1199	N1201	N1207	N1197	
pH	....	8.1	6.9	6.7	6.5	6.7	6.5	5.5 – 8.5
Turbidity	NTU	24.00	0.00	0.00	0.00	0.00	0.00	≤5.00
Colour	PtCo.	449	0	0	0	0	0	≤15
Iron	Mg/l	0.800	0.000	N/R	N/R	N/R	N/R	≤0.300
Residue Aluminium	Mg/l	N/A	0.00	N/R	N/R	N/R	N/R	≤0.20
Free chlorine	mg/L	NA	0.83	0.20	0.23	0.20	0.25	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	70	0	0	0	0	0	0