



NATIONAL WATER & SEWERAGE CORPORATION

WATER QUALITY MANAGEMENT DEPARTMENT

MUBENDE AREA

Report date: 21st July-2016

Table: Water quality for Selected zones in Mityana during the week starting 18th July 2016

Parameter				Monitoring points				National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply			
				C. Valve home land	Bakijul ura	Boma	Kaweri	
CODE		N1403	N1408	N1416	N1420	N1411	N1412	
pH	8.62	6.89	6.55	6.6	6.47	6.67	5.5 – 8.5
Turbidity	NTU	27.00	0.00	0.00	0.00	0.00	0.00	≤5.00
Colour	PtCo.	495	0	0	0	0	0	≤15
Iron	Mg/l	1.33	0.00	N/R	N/R	N/R	N/R	≤0.30
Residue Aluminium	Mg/l	N/A	0.18	N/R	N/R	N/R	N/R	≤0.20
Free chlorine	Mg/L	NA	0.81	0.23	0.21	0.31	0.37	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	15	0	0	0	0	0	0

NA: Not applicable, N/R: Not Reported