



**NATIONAL WATER & SEWERAGE CORPORATION**  
**WATER QUALITY MANAGEMENT DEPARTMENT**  
**MUBENDE WATER AREA**

**Report date:** 30<sup>th</sup> June-2016

**Table:** Water quality for Selected zones in Mubende during the week of 24th June 2016

Parameter	Unit	Raw water	Final water	Monitoring points				National Standard For potable water quality (Water in Supply)
				PSP Simons	Homel and	Bakijuru la	Kaweri	
CODE		N1238	N1243	N1249	N1250	N1256	N1247	
pH	....	8.8	6.6	6.6	6.7	6.6	6.5	5.5 – 8.5
Turbidity	NTU	23.00	0.00	0.00	0.00	0.00	0.00	≤5.00
Colour	PtCo.	421	0	0	0	0	0	≤15
Iron	Mg/l	8.500	0.24	N/R	N/R	N/R	N/R	≤0.300
Residue Aluminium	Mg/l	N/A	0.180	N/R	N/R	N/R	N/R	≤0.20
Free chlorine	mg/L	NA	1.15	1.23	0.35	0.27	0.25	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	368	0	0	0	0	0	0