



# NATIONAL WATER & SEWERAGE CORPORATION

## WATER QUALITY MANAGEMENT DEPARTMENT

### MUBENDE AREA

Report date: 1st November-2016

Table: Water quality for Selected zones in Mubende during the week of 27<sup>th</sup> October 2016

Parameter				Monitoring points					National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water	Water in Supply					
				kasenyi	Boma	Kaweri	Kabasonjo	Katabalanga DE	
Codes		N2056	N2057	N2058	N2059	N2060	N2062	N2063	
pH	....	7.1	7.0	7.2	7.2	7.1	7.2	7.2	5.5 – 8.5
Turbidity	NTU	33.00	0.00	0.00	1.01	2.32	1.03	0.54	≤5.00
Colour	PtCo.	560	0	5	1	11	9	4	≤15
Iron	Mg/l	1.832	0.040	N/R	N/R	N/R	N/R	N/R	≤0.300
Free chlorine	mg/L	NA	1.20	0.42	0.23	0.25	0.20	0.20	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	50	0	0	0	0	0	0	0

N/A-Note Applicable, N/R-Note required.