



**NATIONAL WATER & SEWERAGE CORPORATION
WATER QUALITY MANAGEMENT DEPARTMENT**

MUBENDEAREA

Report date: 10th October, 2016

Table: Water quality for Selected zones in **Mubende** Area during the week ending 6thOctober2016

Parameter				Monitoring points				National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply			
				Baihujur ula	Lubanga	Mainstreet MKT	Kangurumi ra	
Codes		4454	4457	4462	4463	4464	4465	
pH	7.5	6.8	6.7	6.9	6.8	6.8	5.5 – 8.5
Turbidity	NTU	21.5	2.80	1.90	1.30	1.00	1.70	≤5.00
Colour	PtCo.	265	8	6	7	5	6	≤15
Iron	Mg/l	3.20	0.120	N/R	N/R	N/R	N/R	≤0.300
Residue Aluminium	Mg/l	N/R	0.15	N/R	N/R	N/R	NR	≤0.20
Free chlorine	mg/L	N/R	0.60	0.39	0.20	0.22	0.30	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	25	0	0	0	0	0	0

N/A-Not applicable, N/R-Not required.