



**NATIONAL WATER & SEWERAGE CORPORATION  
WATER QUALITY MANAGEMENT DEPARTMENT**

**MUBENDE AREA**

**Report date:** 15<sup>th</sup> September-2016

**Table:** Water quality for Selected zones in Mubende during the week of 8<sup>th</sup> September 2016

Parameter				Monitoring points				National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply			
				PSP Kisekende	Asaab a	Nakivub o	Boma	
CODE		N1840	N1845	N1851	N1853	N1854	N1848	
pH	....	8.5	6.7	6.6	6.8	6.7	6.5	5.5 – 8.5
Turbidity	NTU	40.00	0.00	0.00	0.00	0.00	0.00	≤5.00
Colour	PtCo.	550	0	0	0	0	0	≤15
Iron	Mg/l	0.860	0.000	N/R	N/R	N/R	N/R	≤0.300
Residue Aluminium	Mg/l	N/A	0.100	N/R	N/R	N/R	N/R	≤0.20
Free chlorine	mg/L	NA	1.18	0.33	0.20	0.20	0.24	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	70	0	0	0	0	0	0