

MUBENDE AREA**Report date:** 6th January -2016**Table:** Water quality for Selected zones in Masaka during the week starting 28th December 2015

Parameter				Monitoring points					National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply				
				PSP	C.Valve	Boma	Kaweri	Kasenyi	
CODE		N100	N101	N102	N103	N104	N105	N106	
pH	7.5	6.8	6.6	6.7	6.6	6.8	6.5	5.5 – 8.5
Turbidity	NTU	15.00	0.00	0.00	0.00	0.00	0.00	0.00	≤5.00
Colour	PtCo.	483	0	0	0	0	0	0	≤15
Iron	Mg/l	0.74	0	N/A	N/A	N/A	N/A	N/A	≤0.30
Residue Aluminium	Mg/l	NA	0.04	N/A	N/A	N/A	N/A	N/A	≤0.20
Free chlorine	Mg/L	N/A	1.06	0.27	0.41	0.2	0.32	0.53	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	86	0	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required