



NATIONAL WATER & SEWERAGE CORPORATION

WATER QUALITY MANAGEMENT DEPARTMENT

MUBENDE AREA

Report date: 21st January-2016

Table: Water quality for Selected zones in mubende during the week of 11th January-2016.

Parameter	Unit	Monitoring points							National Standard For potable water quality (Water in Supply)
		Raw water	Final water		Water in Supply				
Codes		N103	N108	N114	N120	N111	N112	N110	
pH	7.2	6.6	6.7	6.7	6.6	6.8	6.5	5.5 – 8.5
Turbidity	NTU	15.00	0.00	0.00	0.00	0.00	0.00	0.00	≤5.00
Colour	PtCo.	318.8	341	0	0	0	0	0	≤15
Iron	Mg/L	0.630	0.000	N/A	N/A	N/A	N/A	N/A	≤0.300
Residue Aluminium	Mg/L	NA	0.14	N/A	N/A	N/A	N/A	N/A	≤0.20
Free chlorine	Mg/L	N/A	0.95	0.22	0.23	0.20	0.21	0.35	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	30	0	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required