



**NATIONAL WATER & SEWERAGE CORPORATION
WATER QUALITY MANAGEMENT DEPARTMENT**

MUBENDE AREA

Report date: 24th Feb 2016

Table: Water quality for Selected zones in **Mubende** during the week of 18th February. **2016**

Parameter				Monitoring points			National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water	Water in Supply			
				Central	kaweri	Kasenye	
Codes		N453	N454	N459	N460	N458	
pH	7.9	7.9	7.4	7.9	7.5	5.5 – 8.5
Turbidity	NTU	16.1	1.04	0.00	0.00	0.00	≤5.00
Colour	PtCo.	305	15	0	0	0	≤15
Iron	Mg/l	0.470	0.120	N/A	N/A	N/A	≤0.300
Residue Aluminium	Mg/l	N/R	0.12	N/R	N/R	N/R	≤0.20
Free chlorine	Mg/L	NR	1.17	0.26	0.23	0.25	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	70	0	0	0	0	0

NA: Not applicable, N/R: Not Required