



**NATIONAL WATER & SEWERAGE CORPORATION
WATER QUALITY MANAGEMENT DEPARTMENT**

MUBENDE AREA

Report date: 9th March 2016

Table: Water quality for Selected zones in **Mubende** during the week of 3rd March. **2016**

Parameter				Monitoring points				National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water	Water in Supply				
				Kaweri dead end	Boma	Kaweri	Kasenyei	
Codes		N460	N465	N477	N468	N469	N457	
pH	8.4	7.4	6.7	6.6	6.7	6.5	5.5 – 8.5
Turbidity	NTU	18.00	0.00	0.00	0.00	0.00	0.00	≤5.00
Colour	PtCo.	250	0	0	0	0	0	≤15
Iron	Mg/l	1.06	0.00	N/A	N/A	N/A	N/A	≤0.300
Residue Aluminium	Mg/l	NA	0.05	N/A	N/A	N/A	N/A	≤0.20
Free chlorine	Mg/L	N/A	1.09	0.20	0.26	0.4	0.34	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	80	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required